



Certificate of Compliance

This certificate is issued for the following:

U-FLEX EXPANSION JOINT, MODELS: KYSUF, KYSUD, KYSUKB, KYSUY

V-FLEX EXPANSION JOINT MODELS: KYSVF, KYSVD, KYSVKB, KYSVY

FOR USE IN ABOVEGROUND FIRE PROTECTION SYSTEMS

SIZES: 25, 32, 40, 50, 65, 80, 100, 125, 150, 200, 250 mm (1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4, 5, 6, 8, 10 inch) NPS

Pressure Rating 1725 kPa (250 psi)

Prepared for:

KAYSE ENDUSTRIYEL MAMULLER SAN. TIC. A.Ş
ORHANLI ORTA MAH. AKTEPE SANAYI SITESI. NO. 12 / B
TUZLA, ISTANBUL, TURKEY

FM Approvals Class: 1920

Approval Identification: 3060418

Date Approved: April 24, 2017

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink that reads 'D. B. Fuller'.

David B. Fuller
VP, Manager – Fire Protection Group
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062 USA



Member of the FM Global Group



Certificate of Compliance

This certificate is issued for the following:

MODEL KMKBYF EXPANSION JOINTS WITH GIMBAL TYPE (KARDAN MAFSALLI TIP)

FOR USE IN ABOVEGROUND FIRE PROTECTION SYSTEMS

SIZES: 25, 32, 40, 50, 65, 80, 100, 125, 150, 200, 250, 300 mm

(1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 4, 5, 6, 8, 10, 12 inch) NPS

Pressure Rating 1725 kPa (250 psi)

Prepared for:

KAYSE ENDUSTRIYEL MAMULLER SAN. TIC. A.Ş
ORHANLI ORTA MAH. AKTEPE SANAYI SITESI. NO. 12 / B
TUZLA, ISTANBUL, TURKEY

FM Approvals Class: 1920

Approval Identification: 3060418

Date Approved: April 24, 2017

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read 'D. B. Fuller', written over a horizontal line.

David B. Fuller
VP, Manager – Fire Protection Group
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062 USA



Member of the FM Global Group